



TECHNICAL POLICY

G – 01 Fire Stopping of Penetrations

Original Issue: September 1988
Revised: April 2006

Where any piping, conduit or ductwork penetrates a fire rated floor or wall, the penetration must be properly fire stopped. The fire stopping materials shall be acceptable to the Minneapolis Building Inspection Department.

Gypsum board and concrete block walls must be fire stopped on both sides and concrete walls should be patched on the side that is exposed to view when work is being done in existing buildings. **Installation details must be shown on the drawings.**