



TECHNICAL POLICY

14 – 07 Protection of Standpipe

Original Issue: July 1986
Revised: April 2006

- Horizontal standpipe piping is to be protected from habitable areas by one hour fire rated construction or by automatic sprinkler protection.
- If the habitable area is not protected by sprinklers, sprinklers may be mounted directly on the standpipe to provide protection for the horizontal run of standpipe.
- Sprinkler protection is required within combustible concealed spaces that contain standpipe piping.

Exception: This policy does not apply to dry standpipe systems in parking ramps.