



## TECHNICAL POLICY

### 13 – 70      Sprinkler Supplied from Standpipe

Original Issue: February 1985  
**Revised: April 2006**

Sprinkler piping supplied from standpipe risers or supply mains are to have a control valve located at the standpipe to allow the shutdown of the sprinkler system while allowing the standpipe to remain in service.

Where the sprinkler system is supplied from a standpipe riser located in a stair enclosure, the sprinkler control valve is to be located in the stair enclosure.