



TECHNICAL POLICY

13 – 50 Test Connections and Drains

Original Issue: February 1985
Revised: April 2006

Water supply test pipes/main drains and inspectors test connections are to be piped to the outside or to a drain that will accept full flow.