



TECHNICAL POLICY

13 – 12 Sprinkler Protection at Floor Openings

Original Issue: February 1985
Revised: April 2006

1. Unenclosed openings through floors in buildings protected by sprinklers are to have close spaced sprinklers located as required by NFPA 13.
2. Draft curtains are not required at the floor openings in light and ordinary areas provided that the sprinklers are quick response type and the draft curtains are not required by the building code.